

NOTICE ABOUT YOUR DRINKING WATER

Disinfection Byproducts Maximum Contaminant Level (MCL) Exceedance

Public Water System Name: New Hampton Village Precinct PWS ID: 1691010

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. The locational running annual average (LRAA) calculation represents the average of all sample results collected at a particular monitoring location during the previous four calendar quarters. The drinking water LRAA calculation is above the enforceable MCL at one or more sites for the following:

Contaminant and MCL	Detected Level	Date Sampled	Highest LRAA	Compliance Period
Total Trihalomethanes (TTHM) 0.080 mg/L				
Haloacetic Acids (HAA5) 0.060 mg/L	0.087	10-01-2019	0.078	Quarter 4-2019

This is not an emergency. If it had been, you would have been notified immediately.

For TTHM violations: *Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney or central nervous system and may have an increased risk of getting cancer.*

For HAA5 violations: *Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.*

It is not necessary to use alternate water; however, if you have specific health concerns, please contact your health care professional. General health related questions may be directed to the EPA Safe Drinking Water Hotline at 1-800-426-4791.

Steps being taken to correct the situation: Awaiting our consultant to perform a pilot study to determine the practicality of adding a coagulant to remedy the issue.

Expected Resolution Date: TBA

Contact Name: Robert Barry, Commissioner

Company: New Hampton Village Precinct

Address: PO Box 506, New Hampton, NH 03256

Telephone Number: 603-744-7921

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example; people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

IMPORTANT NOTICE ABOUT YOUR DRINKING WATER

Monitoring & Reporting Requirements Not Met

Public Water System Name: __New Hampton Village Precinct__ PWS ID: 1691010

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the compliance period noted below, we did not "monitor or test" or "did not complete all monitoring or testing" for the listed contaminants, and therefore cannot be sure of the quality of your drinking water at that time.

Contaminant(s) (What we were supposed to sample for)	Compliance Period (Month or quarter and year we were supposed to sample)	Date sample was or will be collected (If a make-up sample is required)
Lead and/or Copper	Quarter 4, 2019	Quarter 1, 2020

What should I do?

There is nothing you need to do at this time.

Steps being taken to correct the situation: ___Testing is currently being performed___

Expected Resolution Date: __Quarter 1 2020__

Contact Name: _Robert Barry, Commissioner__ Company: _New Hampton Village Precinct__

Address: _PO Box 506, New Hampton NH 03256__ Telephone Number: _603-744-7921__

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.